
Severn Trent Water

SEVERN TRENT WATER Ltd
Great Central Road
Mansfield
NG18 2RJ

10th March 2006

CPM Group Ltd.
Head Office.
Mells Road.
Mells.
Frome.
Somerset.
BA11 3PD.

Tel **0121 722 4000**
Fax **01623 672915**

Direct Line 01623 672824
 07769 881722

Contact Dflint1

Your Ref

Our Ref NPG 2005/3

FAO Mr Mark Flavell

Dear Mark

CPM Ovoid Pipes

I am pleased to inform you that CPM Ovoid Pipes were approved at our January 2006 meeting of the New Products Group for use on public and prospectively adoptable sewers within this Company.

This approval relates to pipes of the nominal internal sizes 400mm x 600mm, 600mm x 900mm and 800mm x 1200mm that are included in your BSI Kitemark Licence KM06910.

I acknowledge your recommendation that the use of Rocker pipes is not advised due to strength of the pipe and accentuated angular deflection that could occur from using short Pipes. If during the use of CPM Ovoid pipes this causes us any concerns I will contact you for advice.



Yours sincerely David Flint
Senior Advisor Capital Liaison

A part of Severn Trent Plc



Registered in England & Wales Registration No. 2366686
Registered Office 2297 Coventry Road Birmingham B26 3PU