



Dŵr Cymru
Welsh Water

PRODUCT GROUP

Approval No. 2008/34

- 1. SUPPLIER** **CPM Group Ltd**
- Address:** Mells Road
Mells
Frome
Somerset
BA11 3PD
- Telephone No:** 01179 814 500
Fax No: 01179 814 511
E-mail: sales@cpm-group.com

2. PRODUCT **Concrete Pipe System**

2.1 Brief Description of Product

CPM Concrete Drainage Pipes

2.2 Approval Granted

- CPM Concrete Drainage Pipes of nominal diameter 225mm to 1,800 mm (inclusive) approved for use in stormwater attenuation / storage systems for both combined flows and storm flows in both on and off-line applications **except** in highways (including estate roads and car parks) where pipes can only be up to 900mm diameter but subject to the limitations described below.

<u>Pipe Component</u>	<u>Diameter</u>
Stop End Bend	900 – 1800mm
Side Entry Manhole	900 – 1800mm
Mid Entry Manhole	900 – 1800mm
Stop End Pipe	900 – 1800mm
End Entry Pipe	1350 – 1800mm

- For off-line stormwater attenuation / storage systems, the manhole diameter may be the same as the pipe diameter subject to a minimum diameter of 1200mm.
- Where third party ancillaries are installed as part of an overall solution e.g. fitting Hydrobrakes, CPM Group Ltd will provide a certificate from such third parties confirming that all their requirements have been met in the stormwater attenuation/storage systems design and that these follow the details agreed with Dŵr Cymru Welsh Water.

Approved:

(for DCWW Product Group)

Date: 1 November 2008