



Dŵr Cymru
Welsh Water

PRODUCT GROUP

Approval No. 2008/35

1. SUPPLIER CPM GROUP LTD

Address: Mells Road
Mells
Frome
Somerset
BA11 3PD
Telephone No: 01179 814 500
Fax No: 01179 814 511
E-mail: sales@cpm-group.com

2. PRODUCT Concrete Weir Wall Flow Control Chamber

2.1 Brief Description of Product

Prefabricated Concrete Weir Wall Flow Control Chamber

2.2 Approval Granted

- Component Weir Wall Flow Control Chamber manufactured in pre-cast reinforced concrete sections with a nominal internal diameter of 2m, 2.55m, 2.74m, 3m and 3.66m: all complying with drawing WWALL/001-2 of Jan 09 and the accompanying specification.
- Weir Wall Flow Control Chamber manufactured in one-piece pre-cast reinforced concrete with a nominal internal diameter of 2.1m: complying with drawing WWALL/002-2 of Jan 09 and the accompanying specification.
- Any Hydro-brake or equivalent flow control unit fitted in the chamber shall be one of Dŵr Cymru Welsh Water's approved products, supplied and fitted in accordance with the terms of the approval granted.
- The benching design in the flow control chambers shall be shown on a drawing to accompany any sewers for adoption submission (see Section 1.5.3 of Sewers for Adoption – 6th Edition).

Approved:


.....
(for DCWW Product Group)

Date: 22 January 2009