

## Wessex Water

Claverton Down Bath BA2 7WW Telephone 01225 526000

Wessex Water  
Claverton Down  
BATH  
BA2 7WW

Direct dial: 01225-526496  
email: john.hayes@wessexwater.co.uk

25 February 2010

K Seymour  
CPM Group Ltd  
Mells Road  
Mells  
Frome  
Somerset BA11 3PD

Dear Sirs,


### **Wessex Water – Product Approval (Sealed Pre-cast “Perfect” Manhole System)**

I am pleased to confirm the CPM “Perfect” manhole system incorporating a pre-cast concrete base and sealed chamber rings/cover slab is approved for use in the Wessex Water region. This approval is based on the CPM technical specification which includes the following requirements:

- All concrete components are kite marked to BS EN 1917 & BS 5911-3
- All joints have an elastomeric seal to BS EN 681-1
- The results of tests for water tightness and resistance to vertical loading shall satisfy the requirements of BS EN 1917

Concrete surround or anti flotation ring/s shall be provided where necessary. This approval is valid until it becomes non-compliant with Sewers for Adoption or any subsequent publication which replaces it.

Yours faithfully



John Hayes



Wessex Water  
a YTL company